



*TOWNSHIP OF MILLSTONE*  
**Construction Department**

*County of Monmouth*  
Michael P. Martin, Construction Official

470 Stagecoach Road  
Millstone Township, NJ 08510  
Phone (732) 917-2953  
Fax (609) 208-2083

## REMOVAL OF UNDERGROUND OIL TANKS RESIDENTIAL

- 1) Tank to be uncovered.
- 2) Top of tank to be removed, interior to be cleaned and free of all sludge.
- 3) Tank to be removed from excavation.
- 4) Inspection to observe the following;
  - A. Interior of tank cleaned.
  - B. Integrity of tank (holes in tank).
  - C. Bottom of excavation to be viewed for any evidence of petroleum products
- 5) Following documentation must be provided for closure of permit
  - A. Sludge dump ticket from licensed hauler.
  - B. Tank dump ticket from scrap metal dealer.
- 6) If tank has leaked or has any evidence of oil within excavation, DEP must be notified immediately with proper remediation to follow. Case # from DEP to be provided with ultimately a NFA letter when site is cleaned.